

Analyte	Units	Regulatory Limit	Range of Detections*	Average Detection*	Violaton (Y/N)	Most Recent Sample Dates**
<b>Inorganic Compounds</b>						
Aluminum	mg/L	0.2	ND	ND	N	Samples collected between 8/18/2023 - 8/29/2023
Alkalinity	mg CaCO3/L	N/A	35 - 121	82	N	
Arsenic	mg/L	0.010	ND - 0.0054	0.001	N	
Barium	mg/L	2	ND	ND	N	
Bromide	mg/L	N/A	ND - 0.9	0.095	N	
Calcium	mg/L	N/A	14.5 - 39.6	20.3	N	
Chloride	mg/L	250	19.5 - 165	54.7	N	
Conductivity	uhmos/cm	N/A	210 - 644	367	N	
Iron	mg/L	0.3	ND - 0.15	0.038	N	
Potassium	mg/L	N/A	1.36 - 2.9	1.84	N	
Magnesium	mg/L	N/A	0.15 - 5.6	4.06	N	
Manganese	mg/L	0.05	ND	ND	N	
Sodium	mg/L	N/A	14.4 - 68	45	N	
Selenium	mg/L	0.05	ND - 0.0197	0.005	N	
Strontium	mg/L	N/A	0.07 - 0.26	0.135	N	
Sulfate	mg/L	250	6.26 - 13	9.91	N	
Total Dissolved Solids	mg/L	500	84 - 344	180.9	N	
Total Hardness	mg CaCO3/L	N/A	54 - 99.5	64.2	N	
Total Suspended Solids	mg/L	N/A	ND	ND	N	
Turbidity	NTU	N/A	ND - 0.75	0.1	N	
Zinc	mg/L	5	ND - 0.03	0.005	N	
<b>Volatile Organic Compounds</b>						
1,1,1-Trichloroethane	ug/L	200	ND	ND	N	Samples collected between 8/15/2023 - 8/28/2023
1,1,2-Trichloroethane	ug/L	5	ND	ND	N	
1,1-Dichloroethene	ug/L	7	ND	ND	N	
1,2,4-Trichlorobenzene	ug/L	70	ND	ND	N	
1,2-Dichlorobenzene	ug/L	600	ND	ND	N	
1,2-Dichloroethane	ug/L	5	ND	ND	N	
1,2-Dichloropropane	ug/L	5	ND	ND	N	
1,4-Dichlorobenzene	ug/L	75	ND	ND	N	
Benzene	ug/L	5	ND	ND	N	
Carbon Tetrachloride	ug/L	5	ND	ND	N	
Chlorobenzene	ug/L	100	ND	ND	N	
cis-1,2-Dichloroethene	ug/L	70	ND	ND	N	
Ethylbenzene	ug/L	700	ND	ND	N	
m,p-Xylene	ug/L	N/A	ND	ND	N	
Methylene Chloride	ug/L	5	ND	ND	N	
o-Xylene	ug/L	N/A	ND	ND	N	
Styrene	ug/L	100	ND	ND	N	
Tetrachloroethene	ug/L	5	ND	ND	N	
Toluene	ug/L	1000	ND	ND	N	
trans-1,2-Dichloroethene	ug/L	100	ND	ND	N	
Trichloroethene	ug/L	5	ND	ND	N	
Vinyl Chloride	ug/L	2	ND	ND	N	
Xylenes, total	ug/L	10,000	ND	ND	N	

\* ND = Non-Detect  
\*\* Earlier sample results not included for clarity.

Total Petroleum Hydrocarbons	mg/l	N/A	ND	ND	N	8/18/2023
------------------------------	------	-----	----	----	---	-----------